

CTL DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s)	Tracking No.	Year
IEC 60598-1:2014+A1:2017	Section 2-3	DSH0826B	2023
Category			
LITE			
Subject	Keywords	Developed by	To be approved
Classification and marking of Class II with Class III detachable parts	- - Class III - Marking - Classification	ETF5	2023 CTL Plenary Meeting
Question			
<p>How a product should be marked and/or classified when it consists of a set of:</p> <ol style="list-style-type: none"> 1. An independent control gear (Class I or Class II) with SELV output and 2. A luminaire (one or more) which is detachable from the control gear (by hand)? 			
Decision			
<ul style="list-style-type: none"> - The independent control gear shall be classified as Class I or Class II; - The luminaire shall be marked as Class III; - The whole product may be marked as Class I or Class II on the package. Another way is to mark the package with the rated voltages of the control gear and the luminaire. Class III marking on the package may be misleading, and if applied alone, the marking will be incorrect; - The control gear shall be tested according to Class I or Class II and the luminaire according to Class III. 			
Explanatory notes			
This decision updates the old decision sheet DSH0826A(2019) to be in line with NEW standard editions.			