

## CTL DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s)	Tracking No.	Year
IEC 60598-2-22/2014	22.6.2 – Annex B	DSH 0972A	2017
<b>Category</b>			
LITE			
<b>Subject</b>	<b>Keywords</b>	<b>Developed by</b>	<b>Approved at</b>
Marking	<ul style="list-style-type: none"> <li>- Rest mode</li> <li>- Capital "B"</li> <li>- Emergency luminaire</li> </ul>	ETF5-OSM/LUM	2018 CTL Plenary Meeting
<b>Question</b>			
<p>Annex B gives an overview of the classification and marking of emergency luminaires as to their construction. Item c) states that capital "B" is used for emergency luminaires including remote rest mode. What identification has to be used in case there is only rest mode (without remote)?</p>			
<b>Decision</b>			
<p>For rest mode only use also capital "B".</p>			
<b>Explanatory notes</b>			
---			